

## View Current Section I Watertube (A,O,D) - Prior to April 2005

Search Range is from 1/1/2003 to 1/31/2003

Number of records found: 7

id	Number Units	Circulation	Watertube Capacity	Watertube Capacity UOM	Watertube Design Pressure	Watertube Operating Pressure	Hot Water Boiler	Super Heater	Super Heater Temp	Primary Fuel	Aux Fuel	Firing Method	Nox Reduction	Sic Number	Installation State or Country
85	2	2	65000	pph	250	175	no	no	saturated	4	3	9			20 Minnesota
86	4	2	65000	pph	200	125	no	no	SATURATED	4	3	9		30	0 Tennessee
87	1	2	275578	pph	1140	910	no	yes	878	2	8	9			29 Oceania
110	1	2	250000	pph	1050	925	no	yes	910	2	0	9		275	33 Virgin Islands
111	1	2	350000	pph	800	640	no	yes	750	15	0	9		30	29 Oklahoma
113	1	2	30000	pph	250	125	no	no	saturated	4	3	9		30	80 Kansas
132	1	2	200000	pph	300	150	no	no	Saturated	4	3	9			28 Pennsylvania

## View Current Section I Watertube (other) - Prior to April 2005

Search Range is from 1/1/2003 to 1/31/2003

Number of records found: 17

id	Number Units	Circulation	Boiler Capacity pph	Boiler Capacity hp	Boiler Capacity btu	Boiler Design Pressure	Boiler Operating Pressure	Hot Water Boiler	Fuel Fired	Aux Fuel Fired	Nox Reduction	Sic Number	Sic Description	Installation State or Country
3552	1	Circulation	517.5	15	502125	150		no	Oil Light	None			80 Hospitals, Medical Centers, Nursing Homes	Montana
3559	1	Forced Circulation	517.5	15	502125	300		no	Natural Gas	None			Unknown (Option available only to equipment of below 20 million Btu (or 600 Bhp)	Pennsylvania
3561	1	Circulation	4830	140	4686500	150		no	Natural Gas	None			0 Nonmanufacturing	Canada
3563	2	Forced Circulation	4830	140	4686500	150		no	Natural Gas	Oil Light			80 Hospitals, Medical Centers, Nursing Homes	Utah
3571	1	Forced Circulation	172.5	5	167375	150		no	Natural Gas	None			Unknown (Option available only to equipment of below 20 million Btu (or 600 Bhp)	Washington
3583	1	Circulation	1380	40	1339000	150		no	Natural Gas	None			80 Hospitals, Medical Centers, Nursing Homes	Washington
3637	1	Forced Circulation	724.5	21	702975	150		no	Natural Gas	None			82 Schools & Colleges	Nevada
3638	1	Forced Circulation	345	10	334750	150		no	Natural Gas	None			Unknown (Option available only to equipment of below 20 million Btu (or 600 Bhp)	Oklahoma
3662	1	Forced Circulation	1725	50	1673750	150		no	Natural Gas	None			Unknown (Option available only to equipment of below 20 million Btu (or 600 Bhp)	Central America
3710	1	Forced Circulation	6555	190	6360250	150		no	Oil Light	Natural Gas			Unknown (Option available only to equipment of below 20 million Btu (or 600 Bhp)	Vermont
3713	1	Forced Circulation	6555	190	6360250	150		no	Oil Light	Natural Gas			Unknown (Option available only to equipment of below 20 million Btu (or 600 Bhp)	Vermont
3717	1	Forced Circulation	327.75	9.5	318012.5	150		no	Natural Gas	None			Unknown (Option available only to equipment of below 20 million Btu (or 600 Bhp)	California
3747	1	Once Through	16	0.46	15525	250	225	no	Natural Gas	Oil Light			20 Food and Kindred Products	Wisconsin
3786	1	Forced Circulation	517.5	15	502125	150		no	Natural Gas	None			Unknown (Option available only to equipment of below 20 million Btu (or 600 Bhp)	Maryland
3787	1	Forced Circulation	2415	70	2343250	150		no	Natural Gas	None			Unknown (Option available only to equipment of below 20 million Btu (or 600 Bhp)	Maryland
3788	1	Forced Circulation	1035	30	1004250	150		no	Natural Gas	None			Unknown (Option available only to equipment of below 20 million Btu (or 600 Bhp)	California
5714	1	Once Through	6900	200	6695000	15		no	Natural Gas	None			80 Hospitals, Medical Centers, Nursing Homes	Minnesota